

**CITY OF LA VISTA**  
**MAYOR AND CITY COUNCIL REPORT**  
**AUGUST 16, 2016 AGENDA**

<b>Subject:</b>	<b>Type:</b>	<b>Submitted By:</b>
EMERGENCY ELECTRICAL REPAIR	◆ RESOLUTION ORDINANCE RECEIVE/FILE	JOE SOUCIE DIRECTOR OF PUBLIC WORKS

**SYNOPSIS**

A resolution has been prepared authorizing the payment for an emergency electrical repair at the Public Works Facility by Vierregger Electric Co, Omaha, Nebraska, for an amount not to exceed \$6,540.00.

**FISCAL IMPACT**

The FY 16 Street, Parks and Sewer Operational Budgets have funding available to cover the expenditure.

**RECOMMENDATION**

Approval

**BACKGROUND**

On July 26, 2016, Morris Excavating was removing the fuel tanks at the Public Works Facility. The electrical supply line running from the main building to the sewer division shop on the east end of the property was inadvertently not marked and subsequently damaged during excavation. Marking of the electrical line was the responsibility of Public Works. A temporary repair was completed on June 26<sup>th</sup>. In order to replace the removed concrete, permanent repairs need to be completed to close out the project.

**RESOLUTION NO. \_\_\_\_\_**

**A RESOLUTION OF THE MAYOR AND CITY COUNCIL OF THE CITY OF LA VISTA,  
NEBRASKA AUTHORIZING THE PAYMENT FOR AN EMERGENCY ELECTRICAL REPAIR  
AT THE PUBLIC WORKS FACILITY BY VIERREGGER ELECTRIC CO., OMAHA  
NEBRASKA IN AN AMOUNT NOT TO EXCEED \$6,540.00**

**WHEREAS, The Mayor and City Council have determined that emergency electrical repairs  
were necessary at the Public Works Facility; and**

**WHEREAS, the FY 16 Street, Parks and Sewer Operational Budgets have funding available  
to cover the expenditure;**

**WHEREAS, Subsection (c) of Section 31.23 of the La Vista Municipal Code requires that the  
City Administrator secure Council approval prior to authorizing any purchase over  
\$5,000.00.**

**NOW, THEREFORE BE IT RESOLVED, that the Mayor and City Council authorize the  
payment for an emergency electrical repair at the public works facility by  
Vierregger Electric Co., Omaha Nebraska in an amount not to exceed  
\$6,540.00**

**PASSED AND APPROVED THIS 16TH DAY OF AUGUST, 2016**

**CITY OF LA VISTA**

---

**Douglas Kindig, Mayor**

**ATTEST:**

---

**Pamela A. Buethe, CMC  
City Clerk**



# VIERREGGER ELECTRIC CO.

POWER • HEAT • LIGHT

4349 SOUTH 139TH STREET

OMAHA, NEBRASKA 68137

(402) 886-8008

FAX (402) 886-8859

August 8, 2016

Mr. Ray Crane  
City of La Vista Public Works Department  
9900 Portal Road  
La Vista, Nebraska 68128

## RE: Replace conductors between Main Building and Sewer Shop

Dear Ray:

Thank you for your recent call on 7-26-16. On that day, our crew made temporary splices to damaged conductors to restore power to the Sewer Shop. These splices probably will not survive long term, and the conductors should be replaced for best results in the future. Based upon Dave Vierregger's visit with you today, we are pleased to present the following Proposal for your consideration.

**SCOPE:** Make minor repairs to conduit as necessary; furnish and install four lengths of #1 AWG THHN copper power conductors, and one length of #6 THHN copper grounding conductor, all approximately 600 Linear Feet.

Materials	\$ 3,660.00
Labor & Equipment (32 hrs @ \$90.00)	<u>2,880.00</u>
Total Quoted Price	\$ 6,540.00

This price is based on a Spot Copper price of \$2.20 per pound on the date shown above. If the commodity price of copper changes significantly between the date of this proposal and the date of your acceptance, we reserve the right to refresh this proposal as necessary to reflect the appropriate commodity price. We would be available to begin this work immediately with your notice to proceed.

Thank you very much for the opportunity to present this proposal. Please do not hesitate to contact us if you have any questions, comments or other requirements, or any time we can be of assistance in any way.

Best regards,

VIERREGGER ELECTRIC CO.

*Tim Vierregger*  
Tim Vierregger